



## Fire Prevention Bureau, Woodbridge Fire Department

418 School Street • Woodbridge, New Jersey 07095  
Business: (732) 602-6050 • Fax: (732) 602-6043  
www.woodbridgefireprevention.org

FIRE • POLICE • MEDICAL  
EMERGENCIES  
DIAL 9-1-1

### Fire Department Connection Sign

**SIGNS.** A metal sign with raised letters at least 1 inch in size shall be mounted on all fire department connections serving automatic sprinklers, standpipes or fire pump connections. Such signs shall read: AUTOMATIC SPRINKLER or STANDPIPES or TEST CONNECTION or a combination thereof as applicable.

**EXISTING BUILDINGS.** On existing buildings, wherever the fire department connection is not visible to approaching fire apparatus, the fire department connection shall be indicated by an approved sign mounted on the street front or on the side of the building. Such sign shall have the letters “FDC” at least 6 inches high and words in letters at least 2 inches high or an arrow to indicated the location. All such signs shall be subject to the approval of the fire code official.

**FDC**

**(Other information as needed)**

Directly under the FDC lettering other information is added as needed, such as the type of system, the areas of the building that the system serves, location, or a directional arrow.

A store name can also be added.